



* OVERFLOW DISCHARGE TO APPROVED DRAINAGE. RCP—SAME CAPACITY AS INLET PIPE.

* MAY BE REQ'D BY CITY ENGINEER

- NOTES:
1. CONSTRUCT DROP INLET BOX TO MATCH WIDTH OF CURB & GUTTER MATCH INSIDE LENGTH OF BOX TO INSIDE LENGTH OF FRAME
 2. D & L I-3516 WITH ADJUSTABLE CURB BOX
 3. STANDARD CAST IRON MANHOLE RING & LID
 4. SUMP DEPTH 36" MIN. FOR < OR = 12" DIA. OUTLET, FOR OUTLET > OR = 15" DIA., DEPTH = 2.5 - 3X DIA.

SECTION A-A

SUMP DISPOSAL AND OIL SEPARATOR

N.T.S.

06/08

HEBER CITY
STANDARD DRAWING
STORM DRAIN-3