

5' FROM PROPERTY LINE OR AS DIRECTED BY ENGINEER

6' FIBERGLASS RED & WHITE STRIPED FIRE HYDRANT REFLECTIVE MARKER

PUMPER NOZZLE

6" WATEROUS WB100 OR MUELLER SUPER CENTURION 250 CAST IRON HYDRANT  
5' BURY UNLESS OTHERWISE SPECIFIED BY CITY ENGINEER

LID

COLLAR TO HAVE TWO #4 BAR CONTINOUS AROUND COLLAR WITH 12" OVERLAP.

GROUND LINE

1/4" - 3/8"

12" MIN.

CONCRETE COLLAR

ASPHALT

3" MIN  
6" MAX

SECURE 12 GAUGE TRACER WIRE WITH METALIC STRAP TO HYDRANT, LEAVING TWO FEET OF ADDITIONAL WIRE COILED BELOW SURFACE

8" BASE COURSE

VALVE BOX

THRUST BLOCK

6" GATE VALVE

TEE-CONNECTED TO MAIN LINE

FL CONNECTION

DO NOT PLUG DRAIN HOLES

THRUST BLOCK

1/2 CUBIC YARD GRAVEL

# FIRE HYDRANTS

N.T.S.

06/08

HEBER CITY  
STANDARD DRAWING  
WATER-1