


- NOTES:
1. FIRE HYDRANT DRAINS SHALL NOT BE CONNECTED TO, OR LOCATED WITHIN, 10 FEET OF SANITARY SEWERS. WHERE POSSIBLE, HYDRANT DRAINS SHALL NOT BE LOCATED WITHIN 10 FEET OF STORM DRAINS.
 2. ALL VALVE NUT EXTENSIONS SHALL BE PINNED OR OTHERWISE LOCKED TO THE VALVE NUT.

H:\Heber City\Std Dwg\2023 September\Std Dwg\WATER-1_Updated.dwg - Fire Hydrants - 9/07/2023 03:43pm - natalier



| | |
|--|--------|
| DATE: | 04/22 |
| SCALE: | N.T.S. |
| 75 NORTH MAIN STREET HEBER CITY, UTAH 84032 (435) 654-0757 | |

FIRE HYDRANTS

WATER-1