


SECTION A-A

NOTES:

1. CONSTRUCT DROP INLET BOX TO MATCH WIDTH OF CURB & GUTTER. MATCH INSIDE LENGTH OF BOX TO INSIDE LENGTH OF FRAME.
2. D & L I-3516 WITH ADJUSTABLE CURB BOX.
3. STANDARD CAST IRON MANHOLE RING & LID.
4. SUMP DEPTH = 36" MIN. FOR 12" DIAMETER OUTLET AND SMALLER, FOR OUTLET DIAMETER 15" AND LARGER, DEPTH = 2.5 TO 3 TIMES THE DIAMETER.
5. SEE STANDARD SPECIFICATION 02772 PONDS.

H:\Heber City\Std Dwg\2023 September\Std Dwg\STORM DRAIN-3 Updated.dwg - Sump Oil - 9/07/2023 03:41 pm - natalier



DATE: 09/23  
 SCALE: N.T.S.  
 75 NORTH MAIN STREET  
 HEBER CITY, UTAH 84032  
 (435) 654-0757

SUMP DISPOSAL & OIL SEPARATOR

DRAIN-3