


TABLE 1					
SERVICE LINE SIZE	MINIMUM METER BOX SIZE	BOX MODEL	FRAME MODEL	COMMENTS	INSULATION INSERTS
1" MINIMUM		SEE THE APPENDIX FOR ALTERNATIVES			790153
1 1/2"	24" x 60"	500VS2460RVB000520N	700098-1	" "	790325
2"	27" x 60"	550VS2760RVB000520N	700098-1	" "	790327


NOTE 1: FOR LARGER SIZES CONTACT PUBLIC WORKS FOR REQUIREMENTS



**NOTES:**

- METER BOX, COVER, COPPER SETTER, CORPORATION STOP, & SERVICE LINES TO BE FURNISHED AND INSTALLED BY DEVELOPER AND CONFORM TO AWWA C800.
- STAINLESS STEEL STIFFENERS ON ALL POLY CONNECTIONS.
- METER BOXES ARE ALLOWED WITHIN DRIVEWAY ZONE ONLY WITH PRIOR APPROVAL FROM PUBLIC WORKS DIRECTOR.
- WATER METER WILL BE INSTALLED BY HEBER CITY.
- SEE UTILS-3 FOR PLAN VIEW.
- WATER METER CAN TO BE LOCATED IN THE MIDDLE OF THE PLANTER STRIP OR BETWEEN SIDEWALK AND PROPERTY LINE (FOR COMBINATION SIDEWALK) OR AS DIRECTED BY ENGINEER.
- WATER SERVICE SHOULD CONNECT DIRECTLY TO THE MAIN LINE AND NOT "TEE" OFF FIRE HYDRANT LINE OR SERVICE LINES.
- WATER METER CAN SHALL BE COMPLETELY BACKFILLED WITH COMPACTED 3" MINUS GRANULAR MATERIAL FROM TOP TO BOTTOM.
- ANY NIPPLES USED FOR SERVICE SHALL BE STAINLESS STEEL.
- METER FEE WILL BE ASSESSED WITH BUILDING PERMIT OR AT TIME OF METER INSTALLATION.
- SEE APPENDIX A FOR ADDITIONAL APPROVED ALTERNATES.

H:\Heber City\Std Dwgs\2023 September\Std Dwgs\WATER-6B\_Updated.dwg - Service 1 Lot - 9/07/2023 03:44pm - natalier



DATE: 09/23  
 SCALE: N.T.S.  
 75 NORTH MAIN STREET  
 HEBER CITY, UTAH 84032  
 (435) 654-0757

WATER SERVICE - SINGLE LOT

WATER-6B